

## **SUPPLEMENTAL/BID BULLETIN No. 1**

### **Site Development Works for the NDC Industrial Estate Project Brgy. Langkaan, Dasmariñas, Cavite Project Reference No.: BAC19-01-004**

This Supplemental/Bid Bulletin No. 1 is being issued to modify and/or amend the DRAWINGS in the Bid Documents. The following drawings have been revised:

- A-1 TABLE OF CONTENTS – Additional drawings D-12, D-13, K-7 and K-8 have been added while L-1 and L-2 have been deleted increasing the total number of sheets from 170 to 172. Subsequent changes are discussed hereafter.
- B-1 LAND USE PLAN and B-2 SITE DEVELOPMENT PLAN – An Emergency Exit Gate to the barangay road have been added at the end of Road 3. The Motor Control Center (MCC) have been deleted. All drawings showing the Site Development Plan have also been revised.
- D-7 Changed to GENERATOR ROOM FLOOR PLAN, ELEVATION AND SECTION
- D-8 Changed to GENERATOR ROOM ROOF DECK PLAN, DOORS AND WINDOW SCHEDULE
- D-12 Added PUMP HOUSE FLOOR PLAN, ELEVATION AND CROSS SECTION
- D-13 Added PUMP HOUSE SECTIONS, DOOR AN WINDOWS SCHEDULE
- H-8 Changed to PUMP HOUSE FOUNDATION PLAN, DECK ROOF FRAMING PLAN, SECTION & DETAILS
- J-1 ELECTRICAL GENERAL NOTES, SYMBOLS AND SCHEDULE – Updated the Load Schedule of the Administration Complex. The Generator Set capacity is now 150 KVA.
- J-7 SCHEMATIC DIAGRAM, ETC, SINGLE LINE DIAGRAM – The single line diagram have been revised.
- J-12 STP SINGLE LINE DIAGRAM – The diagram has been revised
- J-13 STP LOAD SCHEDULE – The load schedule has been revised. The Generator Set Capacity is now 220 KVA.

K-7 Added EMERGENCY GATE, ELEVATION AND DETAILS

K-8 Added EMERGENCY GATE PLAN AND SECTION

This **SUPPLEMENTAL/BID BULLETIN No. 1** is issued this 14 August 2019 for guidance and information of all concerned.

**(SGD.)SATURNINO H. MEJIA**

Chairman

Bids and Awards Committee